

CERTIFICATE OF APPROVAL No CS 5082

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

DOORPAC LTD

2 Ranskill Court, Sheffield, South Yorkshire, S9 5FZ
Tel: 0114 256 1615

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT
Homeguard Internal Security Doorset

TECHNICAL SCHEDULE
STS201 - Enhanced security
requirements for doorsets to satisfy
the requirements of PAS24

CLASSIFICATION			
Security	Weather	Strength	Material Specific
PAS24 D	BS6375-1 800U	BS6375-2&3 Medium Duty	NPD

NPD = No performance determined

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited



Paul Duggan
Certification Manager



Issued: 3rd October 2016
Re-issued: 2nd July 2021
Valid to: 1st July 2026

Page 1 of 5



CERTIFICATE No CS 5082 DOORPAC LTD

Doorpac Ltd – Homeguard Internal Security Doorsets

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above in providing an enhanced security performance to PAS24:2016 Annex A & B, a weather performance of 800U to BS6375-1:2015 and a mechanical strength performance of Medium Duty to BS6375-2:2009, and an additional performance to Annex A & C of BS6375-3:2009.
3. The doorsets are approved on the basis of:
 - i. Initial type testing against PAS24 & BS6375. Element Wednesbury test reports WIL358543, WIL358544, WIL358545, WIL377471, WIL377473, WIL386604, WIL386605, WIL386606, WIL 408316-1, WIL 408316-2, WIL 408317, WIL 408318, WIL 424994, WIL 424995, WIL 424996, WIL 424997, WIL 424998, WIL 424999, WIL 428172, WIL 437491 & WIL 502743
 - ii. Audit testing at the frequency specified in STS 200 & STS 201 where relevant.
 - iii. A design appraisal against STS201 where relevant.
 - iv. Inspection and surveillance of factory production control at 2 Ranskill Court, Sheffield, South Yorkshire, S9 5FZ.
4. This approval is applicable to complete doorsets only.
5. This certification is designed to demonstrate compliance of the doorset specifically with PAS24 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
6. This approval is applicable to single-leaf, glazed or unglazed, open-in & open-out doorsets without sidelights & toplights, with or without letterplates at leaf dimensions up to those given in Table 1.

CERTIFICATE No CS 5082 DOORPAC LTD

Doorpac Ltd – Homeguard Internal Security Doorsets

7. Approved hardware items are:
- 3no. Carlisle Brass Grade 13 ball bearing hinge (44mm & 54mm Strebord leaf)
or 3no. Arrone AR8182 Grade 13 Ball Bearing Hinge (44mm Strebord & Flamebreak leaf)
or 4no. Arrone AR8182 Grade 13 Ball Bearing Hinge (54mm Strebord leaf only)
 - GU Secury automatic A2 multipoint lock
or Salto Mortice Escape Lock XS4 LE7S15 or Salto Mortice Lock XS4 LE7S05
or Salto Mortice Lock XS4 LE7S25
or Dorma 392CE B Night Latch with GK231M Electric Release Keep (all 54mm Strebord leaf only)
 - Salto Networked Electronic Handle range
XS4 E9451/E9450 (with or without internal thumbturn)
or XS4 EB451/EB450 Bluetooth (with or without internal thumbturn),
or XS4 One E9751/E9750 (with or without internal thumbturn)
or Carlisle Brass CSL Range Lever Handle & Securefast / Apecs Security escutcheon SSEDKC
or Consort 'D' shaped pull handle CPHH15, CPHH8 or CPHH9 & Securefast / Apecs Security escutcheon SSEDKC
or Hoppe 3259N-ZA, 3259N-ZA (V4), 3260N-ZA, M3259N-ZA, M3260N-ZA 2* Security Handle
 - Access2 Tigris Premier 3 1* cylinder, Access2 Tigris Premier 3 3* cylinder, Apecs AP 3* cylinder or Apecs XS 1* cylinder
 - Royde & Tucker LP08-44 letterplate
or UAP Limited 'The Soterian' letterplate (both optional)
 - Dorma TS72V BC overhead door closer (44mm Strebord & Flamebreak)
or Geze Boxer concealed closer (44mm Strebord)
or Eurospec Enduromax High Efficiency Concealed Door Closer DCC2024CF/SV (44mm & 54mm Streboard) (all optional)

For the full specification of the product please refer to the constructional specification that accompanies this certificate.



CERTIFICATE No CS 5082 DOORPAC LTD

Doorpac Ltd – Homeguard Internal Security Doorsets

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-in, single leaf – GU Secury lock (Flamebreak & Strebord 44 leaf)	926	2040	44
Open-in, single leaf – Salto mortice locks (Strebord 54 leaf)	926	2040	54
Open-in & open-out, single leaf – Dorma night latch (Strebord 54 leaf)	926	2040	54
Open-in, single leaf – GU Secury lock (Strebord 54 leaf)	987	2264	54

Table 1. Permitted Door Leaf Dimensions

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single 44mm leaf without toplights & sidelights	1000	2085
Single 54mm leaf without toplights & sidelights	1060	2295

Table 2. Permitted Frame Dimensions

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

8. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
9. Labels to the CERTISECURE design referencing CERTISECURE, PAS24 D, Doorpac Ltd, and CERTISECURE certificate No. CS 5082 shall be affixed to each doorset in the prescribed position.



CERTIFICATE No CS 5082
DOORPAC LTD

10. This approval relates to on going production. The doorset and/ its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

Further Information

Further information regarding the details contained in this report may be obtained from Doorpac Ltd, 2 Ranskill Ct, Sheffield, South Yorkshire, S9 5FZ (Tel: 0114 256 1615)

Further information regarding CERTISECURE certification and other approved products can be obtained from Warringtonfire Testing and Certification, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).